

Item 2007 – Existing Curb & Gutter Removal

- .01 DESCRIPTION:** Adhere to Section 206.01 of the MDOT SHA Standard Specifications.
- .02 MATERIALS:** Adhere to Section 206.02 of the MDOT SHA Standard Specifications.
- .03 CONSTRUCTION:** Adhere to Section 206.03 of the MDOT SHA Standard Specifications.
- .04 MEASUREMENT AND PAYMENT:** Adhere to Section 206.04 (c) of the MDOT SHA Standard Specifications.

Item 2008 – Contingent: Undercut and Backfill for MSE Walls

- .01 DESCRIPTION:** Use Contingent: Undercut and Backfill for MSE Walls when undercut is required to reach bedrock as specified on the Construction Drawings.
- .02 MATERIALS:** Mix 1 Concrete for Backfill.
- .03 CONSTRUCTION:** Adhere to Special Provision for Retaining Walls and the Undercut notes on the Construction Drawings.
- .04 MEASUREMENT AND PAYMENT:** Undercut and Backfill for MSE Walls will be measured by the volume of Mix 1 Concrete required to complete the backfill and shall be paid for at the Contract Unit Price Bid per cubic yard. Payment will be full compensation for the undercut excavation, backfill, material, labor, equipment, tools, and incidentals necessary to complete the work.

Item 3037 – Class I Riprap for Bridge Slope Protection, 12” Depth

- .01 DESCRIPTION:** Adhere to Section 312.01 of the MDOT SHA Standard Specifications.
- .02 MATERIALS:** Adhere to Section 312.02 of the MDOT SHA Standard Specifications.
- .03 CONSTRUCTION:** Adhere to Section 312.03 of the MDOT SHA Standard Specifications.
- .04 MEASUREMENT AND PAYMENT:** Adhere to Section 312.04 of the MDOT SHA Standard Specifications.

Item 3050 – 8 Inch Silt Sock

- .01 DESCRIPTION:** Adhere to Section 308.01 of the MDOT SHA Standard Specifications.
- .02 MATERIALS:** Adhere to Section 308.02 of the MDOT SHA Standard Specifications.
- .03 CONSTRUCTION:** Adhere to Section 308.03 of the MDOT SHA Standard Specifications.
- .04 MEASUREMENT AND PAYMENT:** Adhere to Section 308.04 of the MDOT SHA Standard Specifications.

Item 7006 – Temporary Turfgrass Establishment

- .01 DESCRIPTION:** Perform Temporary Turfgrass Establishment as follows: For Phase I areas east of the bridge that are not at final grade or areas that will not be re-disturbed for at least 6 months after seeding operations are completed, establish temporary turfgrass on existing topsoil, subsoil, common borrow, or other existing soil substrate to provide temporary vegetation groundcover.
- .02 MATERIALS:** Adhere to Section 705.03
Use SHA Turfgrass Seed Mix 20.06.07 (a)
- .03 CONSTRUCTION:** Adhere to Section 705.03 of the MDOT SHA Standard Specifications.
- .04 MEASUREMENT AND PAYMENT:** Adhere to Section 705.04 of the MDOT SHA Standard Specifications.

SPECIAL PROVISIONS

CONTRACT NO. RD-PB-244-10

Item 8010 – (4) 4 Inch Schedule 40 Rigid PVC Conduit – Bridge Attached

Item 8011 – (2) 8 Inch Schedule 40 Rigid PVC Conduit – Bridge Attached

Item 8012 – (4) 4 Inch Schedule 40 Rigid PVC Conduit – Trenched

Item 8013 – (2) 8 Inch Schedule 40 Rigid PVC Conduit – Trenched

- .01 **DESCRIPTION:** Adhere to Section 805.01 of the MDOT SHA Standard Specifications.
- .02 **MATERIALS:** Adhere to Section 308.02 of the MDOT SHA Standard Specifications.
- .03 **CONSTRUCTION:** Adhere to Section 308.03 of the MDOT SHA Standard Specifications and **DELETE 805.03.02** Connections and replace with:

805.03.02 Connections. Make conduit runs with as few couplings as standard length will permit. Connect nonmetallic conduit using a solvent welding process.

ADD: The following after paragraph 805.03.10:

805.03.11 Guardrail. Where guardrail is to be placed, reset, removed, or otherwise worked in any manner that tends to disturb the earth, place conduits and wiring only after such work is complete to avoid damage to the electrical work.

805.03.22 TRACER WIRE. Any new underground conduit identified for use by fiber optic cables, or where the conduit is left empty, shall have a #12 AWG solid insulated copper wire installed to serve as a locator wire for future conduit locating activities. If multiple conduits share the same trench, are within 18” of each other, and share common end points, only one of the conduits must have a tracer wire. Tracer wire shall be labeled “TRACER”.

- .04 **MEASUREMENT AND PAYMENT:** Adhere to Section 805.04 of the MDOT SHA Standard Specifications and the following:
INSERT: The following paragraph:

805.04.04 Conduits fittings, bushings, locknuts, clamps, connectors, spacers, couplings, anchors, fasteners, hangers, and other associated accessories shall be incidental to the installation of the conduit and shall not be measured or paid separately.

805.04.05 Tying into existing manholes, junction boxes (concrete barrier wall/parapet mounted or exposed), vaults and handholes will not be measured and the cost shall be incidental to the pertinent proposed conduit item per linear foot and will include all labor, material, equipment, tools and incidentals necessary to complete the work.