



Washington County

M A R Y L A N D

DIVISION OF ENGINEERING

ADDENDUM NO. 1

TO: Interested Parties

FROM: Brennan Garrett, Senior Architectural Project Manager
Division of Engineering

DATE: Wednesday, February 19, 2020

PROJECT: **CONCRETE SLAB REMOVAL AND REPLACEMENT FOR THE BOARD OF ELECTIONS RENOVATION**

Acknowledge receipt of this **Addendum No. 1** by signing in the space provided below and returning with your Bid.

Failure to sign and return with your Bid may subject the Bidder to disqualification. This **Addendum No. 1** forms a part of the Bid Documents, it supplements and modifies them as outlined herein.

This **Addendum No. 1** consists of 3 pages, including this page.

I hereby acknowledge receipt of **Addendum No. 1**:

By: _____ Date _____
Signed Name

Typed Name

Title

For (Firm): _____

Phone Number: _____

ADDENDUM NO. 1

**CONCRETE SLAB REMOVAL AND REPLACEMENT FOR THE
BOARD OF ELECTIONS RENOVATION**

Date Issued: Wednesday, February 19, 2020

**Bids Due: Wednesday, February 26, 2020
4:00 p.m., Local Time**

The following addendum material is hereby made a part of the Bid Documents.

Please note the following changes, information, and/or instructions in connection with the proposed work and submit proposals accordingly.



Brennan Garrett
Senior Architectural Project Manager
Division of Engineering

By Authority of:
Board of County Commissioners
Washington County, Maryland



Scott Hobbs, P.E.
Director
Division of Engineering

ADDENDUM NO. 1

**CONCRETE SLAB REMOVAL AND REPLACEMENT FOR THE
BOARD OF ELECTIONS RENOVATION**

TO: All prime Contractors and all others to whom specifications have been issued.

ITEM 1.01 CHANGES TO THE PROJECT DRAWING

The proposed new concrete slab shall be tied into the existing concrete slab with No. 4 rebar dowels spaced at 24-inches on center and an expansion joint shall be provided along all perimeter walls.

END OF ADDENDUM NO. 1

